EASIPROX+

Standalone Proximity

- Operating voltage 12Vdc
- Black ABS plastic
- Bluetooth
- Internal or external use
- Self-contained

- Read range 5cm
- Fully programmable via master card
- 3 LED displays with audible indication
- Weather resistant: IP67











RESISTANT
- IP 67 -

BLUETOOTH










LED	POWER + DC12-15V	AUDIBLE BEEPS	STATUS
BLUE	POWER ON, STANDBY MODE	1 LONG BEEP	VALID ACCESS, RESET IS COMPLETE
GREEN	UNLOCKED, DOOR ALWAYS UNLOCKED	2 SHORT BEEPS	LOCKING COMPLETE
RED	INVALID ACCESS DOOR ALWAYS LOCKED	3 SHORT BEEPS	INVALID ACCESS
		CONSTANT BEEPING	BLUETOOTH DEVICE VANDALISED DOOR SENSOR IS ON

EASIPROX Stand Alone Reader Operation Manual







Unit: mm

EASIPROX

EASIPROX-ANSI

EASIPROX-980-40


- I. Features
- 1. Memory volume up to 2000 proximity cards/tokens. Reading time approx. 0.5 seconds.
- 2. Programming via Master Card.
- 3. Preventing re-entering the same card.
- 4. Non-volatile memory stores all cards even in the event of total power failure or when the reader is not in use for a long time.
- 5. Epoxy sealed. Standard size of single-gang box.

II. Specification

Operating Voltage	12 VAC/VDC		
Current Draw	Pull In: 70 mA/12 VDC; Holding: 45 mA/12 VDC		
RF Frequency	125 KHz (ABA form code)		
Read Range	10~15 cm (depending on local installation conditions)		
Input	1 contact for Request-To-Exit button		
Output	1 relay (Dry contacts: N.O./N.C./Com.)		
LED Status Indication	2-LED indicators (Yellow & Green / Red); 3-LED indicators		
	(Yellow, Green, Red)		
Memory Volume	2000 proximity cards/tokens		
Format	EM-400x 64-bit Standard R/O or Compatible		
Relay Rating	Max. 5A/250 VAC		
Relay Strike Time	0.7 ~ 42 seconds		
Ambient Humidity	5%~95% (Non-condensing)		
Operating Temperature	-20°C~70°C		
EMC Specification	Meet CE requirement		

III. LED Status Indication

==== - (6.66					
Mode	Signal	Status			
Standby	Yellow & Green LED flash	No Master Card (empty memory)			
	Yellow LED On	Standby			
	Green LED On	Relay strike time			
	Red LED On	Invalid card			
Programming	Green LED flash	Add cards			
	Red LED flash	Delete cards			
	Yellow & Red LED flash	Clear memory			
	Yellow LED flash	Adjustment of relock time (1 ~ 60			
		flashes, 0.7 ~ 42 seconds)			
	Green LED flash	Clear all memory (including Master			
		Card)			



Note:

- 1. It is suggested to use #22~26 AWG insulation wire.
- 2. It is suggested to use a linear power supply unit to prevent the reduction of reading range.
- 3. The door strike or relay must have a varistor or a diode across the door strike terminals to suppress the back EMF of the strike. Failure to do so will damage the relay contacts and electronic components , or even burn the controller.
- 4. Exit button is at N.O. contact.

V. Operation Instruction

1. Set Master Card

Yellow and Green LED flash indicates that the memory is empty. The first card read by the reader will be the Master Card.

Read the Master Card (Yellow LED stay on), enter standby mode

Note: The same Master Card can be used on more than one reader.

2. Add new cards

- 1. Read Master Card once (Green LED stay on for 3 seconds, then flash), enter adding card mode
- 2. Read the new card(s) (relay active \rightarrow successfully adding the new card)
- 3. Read Master Card once (Green LED off, Yellow LED stay on), back to standby mode

Note: It is suggested to use the card of ABA form codes and make a list of the cards added to the reader.

3. Delete cards

- 1. Read Master Card twice within 2 seconds (Red LED stay on for 3 seconds and flash), enter deleting card mode
- 2. Read the card(s) (Green LED stay on → successfully delete cards)
- 3. Read Master Card once (Red LED off, Yellow LED stay on), back to standby mode

4. Clear all memory

- 1. Read Master Card 3 times, each time within 2 seconds of interval (Yellow & Red LED stay on for 3 seconds and flash), enter clearing memory mode
- 2. Read any EM-400x 64-bit R/O compatible card except Master Card (Green LED flash → in the process of clearing all memory, including Master Card)
- 3. Empty memory and back to default value (Yellow & Green LED flash)
- 4. Follow step 1 to set new Master Card

If the Master Card is lost, follow the steps below to clear all memory:

- 1. Turn off the power
- 2. Connect the two black cables and turn on the power
- 3. In the process of clearing all memory, including Master Card (Green LED flash)
- 4. Disconnect the two black cables (Yellow & Green LED flash → memory is empty)

5. Set relock time

- 1. Read Master Card 4 times, each time within 2 seconds of interval (Yellow LED stay on for 3 seconds, then flash), enter relock time setting mode
- 2. Each flash indicates 0.7 seconds. If the relock time is set to 5 seconds, after 7 flashes, read the Master Card once. (Yellow LED stay on), back to standby mode


Note: The longest relock time is 42 seconds (60 flashes). After 60 flashes, the Yellow LED will automatically stay on and go back to standby mode.


VI. TS-980 Tag Simulator (optional)

TS-980 Tag Simulator simulates any card/tag number stored in the memory of the reader. When you plan to delete a lost card/tag from the memory, Tag Simulator is used to transmit the number of the lost card/tag to the reader and then you can begin to delete it from the memory.

For example: delete the card, ABA code 0001206932. Press On/Off continuously. When the screen displays 0001262368, press 0001262368, and press 0001202368.

Repeat the preceding step. When the screen displays \$\frac{0001206932}{0001206932}\$, and the reader enters deleting card mode, press **Send** (The distance between the Tag Simulator and the reader must be within 3 cm.) Card deletion is completed.





Warranty

The product is warranted against defects in material and workmanship while used in normal service for a period of 1 year from the date of sale to the original customer. The GEM policy is one of continual development and improvement; therefore GEM reserves the right to change specifications without notice.

Annex: User List

Slot Number	ABA Form Code	User Name	Note